



**Centrum stavebního inženýrství a.s. Praha,**  
**Centre of Building Engineering Prague, Laboratory in Prague**  
Akreditovaná zkušební laboratoř, Autorizovaná osoba, Notifikovaná osoba, Certifikační orgán  
Accredited Test Laboratory, Authorised Body, Notified Body, Certification Body  
Pražská 16, 102 21 Praha 10, The Czech Republic

**EC-CERTIFICATE OF CONFORMITY**  
**1390 – CPD – 0292/11/P**

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

***Factory made mineral wool products used for  
thermal insulation of buildings  
-boards for external thermal insulation contact systems (ETICS)***  
*(trade marks and type codes according to list given in the annex to the certificate)*

placed on the market by : **Saint-Gobain Isover CZ s.r.o. IČO : 46 50 75 15**  
**Masarykova 197**  
**517 50 Častolovice**

and produced in the factory : **Saint-Gobain Isover CZ s.r.o.**  
**Masarykova 197**  
**517 50 Častolovice**

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the notified body 1390 - Centrum stavebního inženýrství a.s. - has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control .

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard

**ČSN EN 13 162 : 2009**  
**and Annex B and C of the standard ČSN EN 13 172 : 2009**

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on < 12. 01. 2011 > and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

This certificate cancels validity of document: 1390-CPD-0220/09/P.

Notified Body 1390  
Prague, 12. 01. 2011



Ing. Petr Kučera, CSc.  
Deputy of Notified Body 1390



**Centrum stavebního inženýrství a.s. Praha,**  
**Centre of Building Engineering Prague, Laboratory in Prague**  
Akreditovaná zkušební laboratoř, Autorizovaná osoba, Notifikovaná osoba, Certifikační orgán  
Accredited Test Laboratory, Authorised Body, Notified Body, Certification Body  
Pražská 16, 102 21 Praha 10, The Czech Republic

**Annex to the EC-Certificate of Conformity 1390-CPD-0292/11/P**  
**The certificate cover the following products of Saint-Gobain Isover CZ s.r.o.**  
**Masarykova 197, 517 50 Častolovice**

<i>Trade marks</i>	<i>Thermal conductivity <math>W.m^{-1}.K^{-1}</math></i>	<i>Reaction to fire</i>	<i>Type code in accordance with EN 13162</i>
<i>Isover NF</i>	<i>0,042</i>	<i>A1</i>	<i>MW-EN 13162-T5-DS(TH)-CS(10)40-TR90-WS-WL(P)-MU1</i>
<i>Orsil NF</i>			
<i>Isover TF</i>	<i>0,038</i>	<i>A1</i>	<i>MW-EN 13162-T5-DS(TH)-CS(10)40-TR15-WS-WL(P)-MU1</i>
<i>Orsil TF</i>			
<i>Isover TF PROFI</i>	<i>0,036</i>	<i>A1</i>	<i>MW-EN 13162-T5-DS(TH)-CS(10)30-TR10-WS-WL(P)-MU1</i>
<i>Isover NF 333</i>	<i>0,041</i>	<i>A1</i>	<i>MW-EN 13162-T5-DS(TH)-CS(10\Y)30-TR80-WS-WL(P)-MU1</i>
<i>Isover NF 333 V</i>			
<i>Orsil NF 333</i>			
<i>Fasoterm</i>			

Declaration of the product Isover NF 333 V, which is formed as a result of cutting of the product Isover NF 333 is derived from the declared parameters of this product.



Notified Body 1390  
Prague, 12. 01. 2011

  
Ing. Petr Kučera, CSc.  
Deputy of Notified Body 1390