

# AENOR

## Certificate of constancy of performance

# CE

## 0099

### 0099/CPR/A43/0592

In compliance with Construction Products Regulation 305/2011/EU of the European Parliament and of the Council, of 9 March 2011, the notified body AENOR (n. 0099) has issued this certificate to

## SAINT-GOBAIN ISOVER IBERICA, S.L.

registered office CL PRINCIPE DE VERGARA, 132 28002 MADRID (España)

Construction Product Mineral Wool for building equipment and industrial installations

Harmonised Standard EN 14303:2009+A1:2013

Trade Mark CLIMAVER STAR

See annex for more information.

Production site AV DEL VIDRIO, S/N 19200 AZUQUECA DE HENARES  
(Guadalajara - España)

Certification scheme This certificate attests that all provisions under system 1 concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the aforementioned harmonised standard are applied and that the product fulfils all the prescribed requirements set out above.

This certificate will remain valid until its validity date, provided that the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

First issued on 2015-02-16

Last issued on 2021-11-28

Validity date 2022-11-28



Rafael GARCÍA MEIRO  
Chief Executive Officer

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.  
Génova, 6. 28004 Madrid. España  
Tel. 91 432 60 00.- [www.aenor.com](http://www.aenor.com)

Control body accredited by ENAC. Accreditation number: 1/C-PR356

# AENOR

## Certificate of constancy of performance

0099/CPR/A43/0592

### Annex to Certificate

Trade Mark CLIMAVER STAR

Range of thickness	Face A	Reaction to fire as placed on the market for face A	Face B	Reaction to fire as placed on the market for face B	Designation code	Mean Temperature(°C) / Thermal Conductivity (W/mK)
40	Plastified aluminum	B-s1, d0	Black fiberglass	A2-s1, d0	MW-EN 14303-T5-MV1	10/0,032 20/0,033 40/0,036 60/0,039

Original Electronic Certificate

First issued on 2015-02-16  
Last issued on 2021-11-28  
Validity date 2022-11-28

AENOR INTERNACIONAL S.A.U.  
Génova, 6. 28004 Madrid. España  
Tel. 91 432 60 00.- www.aenor.com

Control body accredited by ENAC. Accreditation number: 1/C-PR356